



Arcoflame Oil Burner Certificate

as required by Commercial Standards CS75-56

The Arcoflame Oil Burner, Model No. _____, Serial No. _____, installed at _____
(Address of Installation)

bears a label evidencing compliance with Commercial Standard CS75-56, and has been installed in accordance with the instructions in the manufacturer's installation manual and in conformity with local regulations, codes, and ordinances.

The Boiler (), furnace (), is a _____ Number _____
(Make)
and the heating load consists of:

1. _____ Btu, or _____ square feet steam (), hot water () radiation; and
2. _____ Btu, or _____ square feet of equivalent steam (), hot water () radiation in domestic hot water load; or
3. _____ Btu, or _____ square inches of cross sectional area of warm air supply pipes measured at the furnace take off; or
4. _____ Btu, or _____ square feet of equivalent steam (), hot water () radiation in the following special load:

All necessary permits have been secured, and the installation has been tested in accordance with the test procedure of Commercial Standard CS75-56 and the following readings taken:

CO₂ { Over fire _____
 { At breeching _____ Stack temperatures at breeching _____ °F

Draft { Over fire _____ } inches H₂O Firing Rate _____ gal/hr.
 { At breeching _____ }

All controls and limiting devices have been checked for proper operation _____
Fuel used, Grade No. _____ of Commercial Standard CS12-48.
Field Service equipment smoke scale reading _____
The above test results are certified to be true:

For service call:

(Name)

(Address)

(Telephone)

(Date)

(Name of Company making installation)

Per _____
(Signature)

(Address)

(Telephone)